

CLIMATE ZONE	ENERGY RATING INDEX
3	65

¹ **This table is effective until August 31, 2019.**

TABLE R406.4²
MAXIMUM ENERGY RATING INDEX

CLIMATE ZONE	ENERGY RATING INDEX
3	63

² **The table is effective from September 1, 2019 to August 31, 2022.**

TABLE R406.4³
MAXIMUM ENERGY RATING INDEX

CLIMATE ZONE	ENERGY RATING INDEX
3	59

³ **This table is effective on or after September 1, 2022.**

Sections 5-148 thru 5-155 Reserved

SECTION 6: That the City of Hurst Code of Ordinances be amended by revising Chapter 5, Article V “Electrical Code” by deleting said section where shown below for Chapter 5, Article V “Electrical Code” and replacing said deleted sections and retaining sections as shown below for Chapter 5, Article V “Electrical Code” to read as follows:

ARTICLE V. ELECTRICAL CODE

DIVISION 1. GENERAL

Sec 5-156 Unchanged.

(1) Section 5-157 Definitions; add a definition to read as follows:

CODE OFFICIAL. The officer or other designated authority, charged with the administration and enforcement of this code, or a duly appointed authorized representative.

Section 5-158 thru Sec 5-160 Unchanged.

(2) Section 5-161. General standards; code adopted. Change (b) to read:

(b) NFPA 70, The National Electric Code, 2014 Edition, as published by the National Fire Protection Association, a copy of which is on file in the office of the City Secretary, as amended by section 5-168, is hereby adopted by reference and designated as the electrical code of the city as though such code were copied at length in this article.

Sec 5-162 thru Sec 5-166 Unchanged.

Sec 5-167. Reserved.

Sec. 5-168. Amendments, deletions and changes to the electrical code.

(3) Add 90.4.1 to read as follows:

90.4.1. Notice of violation. The code official is authorized to serve a notice of violation or order to the person responsible for the erection, installation, alteration, extension, repair, removal or demolition of any work regulated by this code that is in violation of the provisions of this code, or in violation of the approved construction documents thereunder, or in violation of a permit or certificate issued under the provisions of this code or the directive of the code official. Such order may direct the discontinuance of the illegal action or condition and the abatement of the violation.

90.4.2 Prosecution of violation. The code official shall request the legal counsel of the City of Hurst to institute the appropriate proceeding at law or in equity to restrain, correct or abate such violation, or to require the removal or termination of the unlawful occupancy of the structure in violation of the provisions of this code or of the order or direction made pursuant thereto. Neither the City nor the Code Official, shall not be required to provide notice as set forth in 90.4.1 prior to instituting the appropriate proceedings, and providing notice shall not be considered an element of the offense or a requirement before prosecution or other legal proceeding.

90.4.3 Violation penalties. Any person who shall violate a provision of this code or shall fail to comply with any of the requirements thereof or who shall erect, install, alter or repair any work regulated by this code in violation of the approved construction documents or directive of the code official, or of a permit or certificate issued under the provisions of this code, shall be guilty of a misdemeanor and upon conviction thereof shall be fined in a sum not to exceed Two thousand dollars (\$2,000.00) for health or safety violations and not to exceed Five Hundred Dollars (\$500.00) for all other violations. Each day that a violation continues shall be deemed a separate offense.

(4) Article 100; add the following to definitions:

Engineering Supervision. Supervision by a Qualified State of Texas Licensed Professional Engineer engaged primarily in the design or maintenance of electrical installations.

(5) Article 100; amend the following definitions:

Intersystem Bonding Termination. A device that provides a means for connecting intersystem bonding conductors for communication systems and other systems to the grounding electrode system. Bonding conductors for other systems shall not be larger than 6 AWG.

(6) Article 110.2; change the following to read as follows:

110.2 Approval. The conductors and equipment required or permitted by this *Code* shall be acceptable only if approved. Approval of equipment may be evident by listing and labeling of equipment by a Nationally Recognized Testing Lab (NRTL) with a certification mark of that laboratory or a qualified third party inspection agency approved by the AHJ.

Exception: Unlisted equipment that is relocated to another location within a jurisdiction or is field modified is subject to the approval by the AHJ. This approval may be by a field evaluation by a NRTL or qualified third party inspection agency approved by the AHJ.

Informational Note No. 1: See 90.7, Examination of Equipment for Safety, and 110.3, Examination, Identification, Installation, and Use of Equipment. See definitions of *Approved, Identified, Labeled, and Listed.*

Informational Note No. 2: Manufacturer's self-certification of equipment may not necessarily comply with US product safety standards as certified by a Nationally Recognized Testing Lab.

Informational Note No. 3: NFPA 790 and 791 provide an example of an approved method for qualifying a third party inspection agency.

(7) Article 210.52(G) (1) Garages: delete the following:

(1) Garages. In each attached garage and in each detached garage with electric power. At least one receptacle outlet shall be installed for each car space.

(8) Article 230.71(A); add the following exception:

Exception: Multi-occupant buildings. Individual service disconnecting means is limited to six for each occupant. The number of individual disconnects at one location may exceed six.

(9) Article 240.91; delete the Article.

(10) Article 300.11; add the following exception:

Exception: Ceiling grid support wires may be used for structural supports when the associated wiring is located in that area, not more than two raceways or cables supported per wire, with a maximum nominal metric designation 16 (trade size 1/2”).

(11) Article 310.15(B) (7); change to read as follows:

(7) This Article shall not be used in conjunction with 220.82.

(12) Article 500.8 (A) (3) changed to read as follows:

500.8 Equipment.

Articles 500 through 504 require equipment construction and installation that ensure safe performance under conditions of proper use and maintenance.

Informational Note No. 1: It is important that inspection authorities and users exercise more than ordinary care with regard to installation and maintenance.

Informational Note No. 2: Since there is no consistent relationship between explosion properties and ignition temperature, the two are independent requirements.

Informational Note No. 3: Low ambient conditions require special consideration. Explosionproof or dust-ignitionproof equipment may not be suitable for use at temperatures lower than -25°C (-13°F) unless they are identified for low-temperature service. However, at low ambient temperatures, flammable concentrations of vapors may not exist in a location classified as Class I, Division 1 at normal ambient temperature.

(A) Suitability. Suitability of identified equipment shall be determined by one of the following:

- (1) Equipment listing or labeling
- (2) Evidence of equipment evaluation from a qualified testing laboratory or inspection agency concerned with product evaluation
- (3) Evidence acceptable to the authority having jurisdiction such as a manufacturer's self-evaluation or an engineering judgment signed and sealed by a qualified licensed Professional Engineer in the State of Texas.

Informational Note: Additional documentation for equipment may include certificates demonstrating compliance with applicable equipment standards, indicating special conditions of use, and other pertinent information.

(13) Article 505.7 (A) changed to read as follows:

505.7 Special Precaution.

Article 505 requires equipment construction and installation that ensures safe performance under conditions of proper use and maintenance.

Informational Note No. 1: It is important that inspection authorities and users exercise more than ordinary care with regard to the installation and maintenance of electrical equipment in hazardous (classified) locations.

Informational Note No. 2: Low ambient conditions require special consideration. Electrical equipment depending on the protection techniques described by 505.8(A) may not be suitable for use at temperatures lower than -20°C (-4°F) unless they are identified for use at lower temperatures. However, at low ambient temperatures, flammable concentrations of vapors may not exist in a location classified Class I, Zones 0, 1, or 2 at normal ambient temperature.

(A) Implementation of Zone Classification System. Classification of areas, engineering and design, selection of equipment and wiring methods, installation, and inspection shall be performed by a qualified licensed Professional Engineer in the State of Texas.

(14) Article 517.30 Essential Electrical Systems for Hospitals; create a new (H) and add the following language:

(G) Coordination. Overcurrent protective devices serving the equipment branch of the essential electrical system shall be coordinated for the period of time that a fault's duration extends beyond 0.1 second.

Exception No. 1: Between transformer primary and secondary overcurrent protective devices, where only one overcurrent protective device or set of overcurrent protective devices exists on the transformer secondary.

Exception No. 2: Between overcurrent protective devices of the same size (ampere rating) in series.

Informational Note: The terms coordination and coordinated as used in this section do not cover the full range of overcurrent conditions.

(H) Selective Coordination. Overcurrent protective devices serving the life safety, and critical branches of the essential electrical system shall be selectively coordinated with all supply-side overcurrent protective devices.

Exception No. 1: Between transformer primary and secondary overcurrent protective devices, where only one overcurrent protective device or set of overcurrent protective devices exists on the transformer secondary.

Exception No. 2: Between overcurrent protective devices of the same size (ampere rating) in series.

Informational Note: The terms coordination and coordinated as used in this section do not cover the full range of overcurrent conditions.

(15) Article 680.25(A) changed to read as follows:

680.25 Feeders.

These provisions shall apply to any feeder on the supply side of panelboards supplying branch circuits for pool equipment covered in Part II of this article and on the load side of the service equipment or the source of a separately derived system.

(A) Wiring Methods.

(1) Feeders. Feeders shall be installed in rigid metal conduit, intermediate metal conduit.

The following wiring methods shall be permitted if not subject to physical damage:

- (1) Liquidtight flexible nonmetallic conduit
- (2) Rigid polyvinyl chloride conduit
- (3) Reinforced thermosetting resin conduit
- (4) Electrical metallic tubing where installed on or in a building
- (5) Electrical nonmetallic tubing where installed within a building
- (6) Type MC Cable where installed within a building and if not subject to corrosive environment
- (7) Nonmetallic-sheathed cable
- (8) Type SE cable

Sec. 5-169 thru 5-173 Unchanged.

Sec. 5-174 thru 5-185. Reserved.

DIVISION 2. ELECTRICAL INSPECTOR

Sec. 5-186 Unchanged.

Sec. 5-187 Reserved.

Sec. 5-188 thru 5-195 Unchanged.

Sec. 5-196 thru 5-205. Reserved.

DIVISION 3. RESERVED

Sec. 5-206 thru 5-225. Reserved.

DIVISION 4. REGISTRATION OF ELECTRICIANS; CERTIFICATE

Sec. 5-226. thru 5-240. Unchanged.

Sec. 5-241 thru 5-250. Reserved.

DIVISION 5. WORK PERMITS

Sec. 5-251 thru 5-260 Unchanged.

Sec. 5-261 thru 5-275. Reserved.

SECTION 7: That the City of Hurst Code of Ordinances be amended by revising Chapter 5, Article VI “Reserved” by deleting the current Chapter 5, Article VI “Reserved” replacing said deleted sections and retaining sections as shown below for Chapter 5, Article VI “International Pool and Spa Code” to read as follows:

ARTICLE VI. INTERNATIONAL POOL AND SPA CODE

DIVISION 1. GENERAL

Sec. 5-276. International Pool and Spa Code– Adopted. The International Pool and Spa Code, 2015 Edition as published by the International Code Council, Inc., a copy of which is on file in the office of the City Secretary, as amended by Sec. 5-277, administered and enforced by the office of the building official is hereby adopted by reference and designated as the Pool and Spa Code of the City as though such code were copied at length in this article.