



2015 IECC PERFORMANCE TESTING COMPLIANCE CERTIFICATE

Job Address: _____ Date: _____

Permit Number: _____

DUCT LEAKAGE TESTING VERIFICATION

Choose option used for compliance: per 2015 IECC Section R403.3.4, system tested @ 25 Pascals across, including the manufacturer's air handler enclosure.

Rough-in test Option (see code for test specifics) Results of test: _____ CFM

Post Construction Option (see code for test specifics): Results of test: _____ CFM

I certify that I have conducted a **duct blaster test and it has passed the requirements of the 2015 International Energy Conservation Code**. I further certify that I am certified to perform duct testing, leakage test certified by national or state organizations as approved by the Building Official. I certify I am an independent third – party entity, and have not installed the HVAC system; nor am I employed or have any financial interest in the Company that constructs the structure.

Certification Number – Agency: _____

Printed Name of Inspector / Testing Technician: _____

Signature of Inspector / Testing Technician: _____

BUILDING THERMAL ENVELOPE LEAKAGE TESTING VERIFICATION

Compliance requirements: per 2015 IECC Section R402.4.1.2, building thermal envelope tested @ 50 Pascals in accordance with ASTM E779 or ASTM E1827 to verify an air leakage of not exceeding three air changes per hour.

Building Thermal Envelop Leakage Testing: Results of Test: _____ air changes per hour

I certify that I have conducted an **air leakage test and it has passed the requirements of the 2015 International Energy Conservation Code**. I further certify that I am certified to perform air infiltration testing certified by national or state organizations as approved by the Building Official. I certify I am an independent third – party entity, nor am I employed or have any financial interest in the Company that constructs the structure.

Certification Number – Agency: _____

Printed Name of Inspector / Testing Technician: _____

Signature of Inspector / Testing Technician: _____